



Town of Happy Valley-Goose Bay
Policy Statement

Index: Public Works		Policy Number: PW0003	
Approved Date: October 30, 2000	Effective Date: October 30, 2000	Revision Date: May 28, 2013	
Authority: 10th Council of the Town of Happy Valley-Goose Bay		Page 1 of 1	

Topic: MUNICIPAL SERVICES INSTALLATION REGULATIONS-THAWING OF WATER LINES

Policy Statement:

1. Before town personnel proceed with the thawing of any water service lines the applicant must have the following in place:
 - a) A union on waterline above interior shut off valve.
 - b) Ground wire disconnected from water line.
 - c) Ground wire disconnected from any adjoining building or any building between the fire hydrant connection and the connection to be thawed.
 - d) Tenants must have permission from property owners.
 - e) Homeowner must sign PW0024

Unless these conditions are satisfied thawing may not be attempted by town employees.